CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

TIRE ENGINEERING - BOILDING WATERIALS EISTING T

LISTING SERVICE

LISTING No: 7315-1214:100 Page 1 of 1

CATEGORY: Power Units

LISTEE: Alarm-Saf, 65A Industrial Way, Wilmington, MA 01887-3499

Contact: *Joe Holland (978) 658-6717 Fax (978) 658-8638

DESIGN: Models AS/PS5-BFS-12 and AS/PS5-BFS-24 power supply/battery charger devices.

Refer to listee's data sheet for detailed product description and operational

considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, circuit ratings and UL label.

APPROVAL: Listed as supplemental power supply units for use with separately listed compatible fire

alarm control units. Not suitable for use on indication/notification circuit.



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

*Rev. 06-19-2002

Date Issued: JUNE 16, 2003 Listing Expires June 30, 2004

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager